

 <b>Oakdale Electric Cooperative</b>		<b>Board Policy</b>
<b>Policy Name: System Disturbance and Motor Starting</b>		<b>Policy No: 6.08</b>
<b>Last Reviewed/Revised: 07-27-2023</b>		<b>Page 1 of 1</b>

It shall be the general policy of this cooperative that:

The consumer shall not use the service in any way that causes a safety hazard, endangers the Cooperative's facilities, or disturbs service to other consumers. Failure to comply with this provision may result in discontinuance of the consumer's service.

The consumer shall install only such motors or other apparatus or appliances as are suitable for operation with the character of the service supplied by the Cooperative, and electric energy must not be used in such manner as to cause detrimental voltage fluctuations or disturbances on the Cooperative's distribution system.

To facilitate this policy;

- a. A single-phase motor will be served without restriction if the motor is of a size that is 10 horsepower or less and the starting code letter is A, B, C, D, E or F.
- b. A three-phase motor served from a three-phase service will be served without restriction if the motor is of a size that is 30 horsepower or less and the starting code letter is A, B, C, D, E or F.
- c. For all other installations, the Cooperative must be notified in advance of such installation. The Cooperative shall evaluate the possible impact of the proposed installation, and may impose restrictions on the installation or operation of such equipment if service to other consumers will be affected.

<b>Issued:</b> 09-18-89	<b>Reviewed Date (no revisions):</b> 02-24-93, 07-29-2020, 07-27-2023	<b>Revised Date:</b> 04-25-01
----------------------------	---	----------------------------------